

The proposed method of redesigning an insulated neutral system with a voltage transformer consists in that, for producing the neutral terminal, a voltage divider is used that is installed instead of the transformer. The advantage of the proposed method consists in excluding the possibility for the formation of resonance circuits through the inductance of the transformer windings and the capacity of the collecting buses, and as a result, the possibility for the damage of the transformer due to resonance processes.