

Method for increase of power effectiveness of refrigeration installations at cooling gas medium in closed premises is in use of two modes of cold takeoff from cooler of cooling machine. Cold takeoff from cooler at operation of cooling machine is realized in forced way by means of blower, and at not operating refrigeration machine cold takeoff from cooler takes place due to natural air convection.